



James K. Sweeney
 Chief Engineer
Peter K. Sweeney
 Project Engineer

No.	Date	Revised	Approved

Engineering Department
 Design Division

THE WORLD TRADE CENTER
 ELECTRICAL/HVAC
 UPGRADE PROGRAM


Title
TOWERS ONE AND TWO
 74TH FLOOR
 EXISTING AND NEW
 PIPING PLAN
 ASBESTOS ABATEMENT

The drawing is subject to conditions of contract. All inventions, ideas, designs and methods herein are reserved to Fort Authority and may not be used without its written consent.


L.A.V.	L.R.U.	L.A.V.
Designed by	Drawn by	Checked by

Date 5/1/95 Scale N.T.S.


Contract Number
 WTC-802.071
 Drawing Number
 EA-11




TOWER NO. 1 - PIPING PART PLAN - 74TH FLOOR SOUTH



TOWER NO. 1 - PIPING PART PLAN - 74TH FLOOR NORTH



TOWER NO. 2 - PIPING PART PLAN - 74TH FLOOR WEST




TOWER NO. 2 - PIPING PART PLAN - 74TH FLOOR EAST

LEGEND	
-----	NEW PIPING TO BE INSTALLED
-----	EXISTING PIPING TO BE REMOVED
☒	FLOOR DRAIN TO BE REMOVED

NOTES:

1. ASBESTOS-CONTAINING SPRAYED-ON FIREPROOFING IS LOCATED ON THE CEILING DECKING IN THESE AREAS.
2. PRIOR TO THE REMOVAL OF PIPING INSULATION, THE ENGINEER SHALL VERIFY CONTENT OF ASBESTOS. ANY REMOVAL OF ASBESTOS-CONTAINING MATERIAL SHALL BE PERFORMED ON A NET COST BASIS, AS DIRECTED BY THE ENGINEER. FOR COMPUTATION OF NET COST SEE THE SECTION OF DIVISION 1 ENTITLED "NET COST WORK".

I HEREBY CERTIFY THAT THIS IS A TRUE AND CORRECT COPY OF ONE OF THE CONTRACT DRAWINGS CONSTITUTING A PART OF THE CONTRACT NO. WTC-802.071 IN THE FORM IN WHICH SAID DRAWINGS EXISTED AT THE TIME THE SAID CONTRACT WAS EXECUTED BY THE PARTIES.
 DATE 6/22/95 *Samuel A. Aslam* SPEC. WRITER
 DATE 6/15/95 *Peter K. Sweeney* ENGINEER OF DESIGN



KEY PLAN